

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0075:171 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653
Contact: Larry Flood (203) 484-1200

DESIGN: Models RZA-5F, RZA-4XF Remote Zone Annunciator and LED-10, LED-10L Remote Fire Annunciator. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The RZA-5F and *RZA-4XF are intended to be installed on a standard listed single gang electrical back box. The LED-10 and LED-10L are intended to be installed on a three gang electrical back box.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as remote annunciators for use with listee's separately listed electrically and functionally compatible fire alarm control units.

*Corrected 12-03-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 10, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager